



## CEFL PIR 10VDC

White 1500W  
Quicklink: Q1C33

### General

Colour	White
Construction	Plastic
IP Rating	IP00

### Dimensions

Cable Length	2m
Cut Out	64mm (Diameter)
Depth	68mm
Diameter	72mm

### Electrical

Amperage	6A
Maximum Wattage	1500W
Voltage	240V

The PIR Flush Mounted Occupancy Switch with 1-10V Daylight Linked Dimming is a passive infrared switch that dims between 1-10V depending on light levels. Bring lights on only when area is occupied, then automatically dims lights according to ambient light level. This maintains a constant brightness of between 100 and 1000 lux, which can be adjusted. The time lag before switching off can also be adjusted. Please see technical tab for more information.

For suspended or plasterboard ceilings. This product is designed to control dimmable high frequency fluorescent ballasts. Can be connected to any load type up to 6 amps (1500W). For ceilings between 2.2 and 5m in height, a diameter around the sensor of 5m is where the infrared sensor operates at its strongest.

## Technical

Make sure power is switched off from the circuits you are working on by removing appropriate fuses, or switching off appropriate isolating switches.

There is an adjustment spindle on the switch. This is marked LUX, and adjusts the range over which brightness changes. This can only be adjusted in situ, and ideally with the aid of a lux meter so that the desired range of brightness levels are achieved under the luminaire(s) being controlled.

There are also two adjustment spindles on the side of the switch labelled TIME and LUX. TIME: Setting the 'TIME' adjustment determines how long the lights remains on after the switch has lost detected movement. This ranges from 10 seconds to 40 minutes in nine discrete steps as follows: 10, 20, 40, 80, 160 seconds, 5, 10, 20, 40 minutes. (These times are approximate to +/- 20%).

LUX: Incorporated into the switch is a photocell override function which stops the lights coming on whenever there is sufficient daylight. If the 'LUX' knob is set fully anticlockwise the lights will come on no matter how bright it is in the room. With the knob turned clockwise it has to get darker in the room before the occupancy switch will be able to turn the lights on.

Turn on the power, when the switch will come on for about a minute for an automatic walk test. Stand away from the switch for a couple of minutes until the switch turns off. Movement near the switch should then cause it to switch on (subject to the room brightness and photocell setting), and then, if there is no more movement, it will go off after the set time lag.

## Recessed Sensors

PIR Occupancy Switch with 1-10V Daylight Linked Dimming  
White 1500W

---



**MR. RESISTOR**<sup>®</sup>  
Lighting Specialist Est. 1968

The detection range is in a cone approximately 2.5m to 3.5m radius as floor level when mounted between 2 to 3m above the floor.

It should be mounted over the area where activity is expected, such as over a desk.